

BACKFLOW PREVENTOR AND VAULT SECTION A-A

FIRE LINE SIZE	MINIMUM PIT DIMENSIONS			ACCESS DOOR SIZE
	LENGTH	WIDTH	DEPTH	
6 INCH	8'-0"	6'-0"	6'-6"	BILCO JD/2 4'-0" x 4'-0"
8 INCH	9'-0"	6'-0"	7'-0"	BILCO JD/2 4'-0" x 4'-0"
10 INCH	10'-0"	6'-0"	7'-6"	BILCO JD/3 4'-0" x 6'-0"

NOTE: VAULT SHALL BE LOCATED IN A NON-TRAFFIC AREA.

NOTE: DIMENSIONS LISTED IN THE TABLE ARE THE ABSOLUTE MINIMUM DIMENSIONS. DESIGN DIMENSIONS FOR ANY SPECIFIC INSTALLATION SHALL BE DETERMINED BY TOTALING UP THE LENGTH OF THE BACKFLOW PREVENTOR AND ALL FITTINGS AND REQUIRED CLEARANCES WITHIN THE VAULT.

